

Certificado de Conformidad

Por medio del certificado de producto número / By the product certificate number

Nº 2622/0288-B-CER

Emitido a / Issued to:

Titular del certificado / License holder: **FOXESS CO., LTD.**

No.939, Jinhai Third Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang, China

Marca / Trademark:



Fábrica / Manufacturer:

FOXESS CO., LTD.

No.939, Jinhai Third Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang, China

Se certifica que el product / It is certified that the product:

Tipo de aparato / Type of product: **PV Grid-tied Inverter**

Modelos / Models: **T3-G3 / T4-G3 / T5-G3 / T6-G3 / T8-G3 / T8(Dual)-G3 / T10-G3 / T10(Dual)-G3 / T12-G3 / T12(Dual)-G3 / T15-G3 / T17-G3 / T20-G3 / T23-G3 / T25-G3**

Datos técnicos / Rated characteristics:

Potencia nominal / Rated Power

Ver página 2 / See page 2

Tensión nominal / Rated Voltage

Ver página 2 / See page 2

Frecuencia nominal / Rated Frequency

50 Hz

Versión Firmware / Firmware version

Master: V1.18, Slave: V1.00, ARM: VA.08

Número de fases / Number of phases

Trifásico / Three Phases

Transformador de aislamiento / Isolation transformer

No / No

Está en cumplimiento con los requisitos de la norma y regulación / Is in compliance with the requirements of standard and regulation:

- **RD 647/2020**, de 7 de julio, por el que se regulan aspectos necesarios para la implementación de los códigos de red de conexión de determinadas instalaciones eléctricas. ⁽¹⁾

⁽¹⁾ **Observación:** Siendo **SOLO** certificado los requisitos para funciones de protección ante variaciones anormales de tensión y frecuencia, auto reconexión y factor de potencia en la red según viene definido en el Real Decreto 647/2020 / ⁽¹⁾ **Remark:** Being **ONLY** certified the protective functions requirements for voltage and frequency abnormal variations, Self-reconnection and Power Factor in the grid stated in the Real Decreto 647/2020.

El equipo antes mencionado está certificado conforme con el procedimiento interno 4 de SGS de acuerdo con los requisitos de la norma UNE-EN ISO / IEC 17065. / The above-mentioned generating unit is certified according to the SGS internal procedure 4 based on the requirements of the UNE-EN ISO / IEC 17065.

Este certificado se emite por vez primera: 24 de junio de 2022. / This certificate is first issued on 24th of June 2022.

Este certificado es válido hasta: 24 de junio 2027. / This certificate is valid until the 24th of June 2027.

Madrid, 24 de junio de 2022.

Daniel Arranz Muñiz
Certification Manager



Lista completa de referencias con las características nominales de los productos certificados / Full list of product references and nominal characteristics:

Model	T3-G3	T4-G3	T5-G3	T6-G3	T8-G3/ T8(Dual)-G3	T10-G3/ T10(Dual)-G3
Input (DC)						
Max. input current [A]	14/14	14/14	14/14	14/14	14/14 28/28	14/14 28/28
Max.DC Voltage [V]	1100					
MPPT Voltage Range [V]	140-1000					
Output (AC)						
Rated AC Output Power [W]	3000	4000	5000	6000	8000	10000
Max AC Output Apparent Power [VA]	3300	4400	5500	6600	8800	11000
Nominal Grid Voltage	3/N/PE, 220/380, 230/400, 240/415 V					
Nominal Frequency [Hz]	50/60 Hz					

Model	T12-G3/ T12(Dual)-G3	T15-G3	T17-G3	T20-G3	T23-G3	T25-G3
Input (DC)						
Max. input current [A]	14/14 28/28	28/28	28/28	28/28	28/28	28/28
Max.DC Voltage [V]	1100					
MPPT Voltage Range [V]	140-1000					
Output (AC)						
Rated AC Output Power [W]	12000	15000	17000	20000	23000	25000
Max AC Output Apparent Power [VA]	13200	16500	18700	22000	25300	27500
Nominal Grid Voltage	3/N/PE, 220/380, 230/400, 240/415 V					
Nominal Frequency [Hz]	50/60					

